



DISTRICT LEVEL WATER ANALYSIS LABORATORY,
UP JAL NIGAM (RURAL)

Address-Office of Executive Engineer, Construction Unit U.P. Jal Nigam
Near Gandhi Park District - Saharanpur -247001



Certificate Number : **TC-14290**

TEST REPORT (WATER)

Report Number :-	C/2025/June/325	Issue Date :-	30.6.2025	Page No.01
Office Name And Address	Saraswati Vihar Senior Secondary School, Saharanpur			
Customer Name	Saraswati Vihar Senior Secondary School, Saharanpur			
Ref Letter No.& Date.	Date-28.06.2025			

Basic details of sample

District	Saharanpur	Block	NA
Gram Panchayat	NA	Village/ Town/City	NA
Habitation	Saraswati Vihar Senior Secondary School, Saharanpur	Location	Saraswati Vihar Senior Secondary School, Saharanpur
Water Source	Water Cooler	Sample No.	01
Quantity Of Sample	01 Litter	Date of Sample Collection	28.06.2025
Receiving Date	28.06.2025	Sample Collector	Arun Kumar (Saraswati Vihar Senior Secondary School)
Sample Depositor	Pravindra Kumar	Sampling Method	NA
Analysis Start Date	30.06.2025	Analysis Completion Date	30.06.2025

Technical Data of Analysis.

S. No.	Analyzed Parameters	Units of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH (Temp. 25°C)	-	7.38	6.5-8.5	No Relaxation	IS 3025 (Part 11) : 2017
2	Turbidity	NTU	3.4	1.00	5.00	IS 3025 (Part 10) : 2017
3	TDS (Temp. 180°C±2°C)	mg/L	218	500	2000	IS 3025 (Part 16) : 2017
4	Chloride (as Cl)	mg/L	18	250	1000	IS 3025 (Part 32) : 2019
5	Total Alkalinity (CaCO ₃)	mg/L	240	200	600	IS 3025 (Part 23) : 2019
6	Total Hardness (CaCO ₃)	mg/L	260	200	600	IS 3025 (Part 21) : 2019
7	Calcium (as Ca)	mg/L	56	75	200	IS 3025 (Part 40) : 2019
8	Magnesium (as Mg)	mg/L	24	30	100	APHA 24 th Edition-3500-Mg Method B (By Calculation)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Parameter above permissible Limit are written in Bold.
6. **Sample is not Collected by Laboratory.**

(Amit Kumar)
(Reviewed By)

(Amit Kumar)
(Prepared By)

(Amit Kumar)
(Authorized Signatory)

Laboratory Contact Details:

Name – Deeksha Goyal

Email Id: deekshaaggarwal5732@gmail.com

Mob: 7302305330

*******End of the Report*******

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30/6/2025

It is certified that an inspection team headed by SFI RAJESH SINGH

(Name of Officers with designation) from Nagar Nigam, Medical Health PHED

inspected the Branch of Saraswati Vihar Sr. Sec. School, maxikalan, Saharanpur

(Name & Address of the school) on 30/6/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. C/PHED/7028/325 dated 30/6/2025

of UP JOD Nigam (Rajpur) at Ganshi Bazar

of Nagar Nigam, Saharanpur (PHED Lab) certified that the

Branch of Saraswati Vihar Sr. Sec. School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 29/6/2026

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

To

Branch of Saraswati Vihar Sr. Sec. School, maxikalan, Delhi Road, Saharanpur

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies